

)'(

DHS

Oregon Department
of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2 ENTRY POINT Entry Point: EP-B PWS ID 4100246B System Name: <u>Creswell, City of</u> Sample period: <u>November-23</u> Month/year												
1	7.5	45	N/A	N/A	YES		<p>Number of excursions during this month: <u>0</u> <i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.</i></p> <p>Reference: Minimum pH set on 11/3/2003 By John Potts. Minimum Alkalinity set on 2/1/2023 by Amy Bleekman</p> <table border="1"> <tr><td colspan="2">Minimum Water Quality</td></tr> <tr><td colspan="2">Parameter(s) as set by State:</td></tr> <tr><td>pH</td><td>7.1</td></tr> <tr><td>Alk</td><td>33 (Alkalinity)</td></tr> <tr><td>PO4</td><td>N/A (Orthophosphate)</td></tr> <tr><td>Sili</td><td>N/A (Silicate)</td></tr> </table> <p>Print Name: Mike Howard</p> <p>Signature: Mike Howard</p> <p>541-736-6015</p> <p>12/1/2023</p>	Minimum Water Quality		Parameter(s) as set by State:		pH	7.1	Alk	33 (Alkalinity)	PO4	N/A (Orthophosphate)	Sili	N/A (Silicate)
Minimum Water Quality																			
Parameter(s) as set by State:																			
pH	7.1																		
Alk	33 (Alkalinity)																		
PO4	N/A (Orthophosphate)																		
Sili	N/A (Silicate)																		
2	7.5	40	N/A	N/A	YES														
3	7.5	40	N/A	N/A	YES														
4	7.5	40	N/A	N/A	YES														
5	7.4	40	N/A	N/A	YES														
6	7.3	41	N/A	N/A	YES														
7	7.7	42	N/A	N/A	YES														
8	7.8	36	N/A	N/A	YES														
9	7.7	38	N/A	N/A	YES														
10	7.7	38	N/A	N/A	YES														
11	7.6	41	N/A	N/A	YES														
12	7.6	42	N/A	N/A	YES														
13	7.5	40	N/A	N/A	YES														
14	7.3	41	N/A	N/A	YES														
15	7.3	37	N/A	N/A	YES														
16	7.4	38	N/A	N/A	YES														
17	7.4	40	N/A	N/A	YES														
18	7.4	40	N/A	N/A	YES														
19	7.4	40	N/A	N/A	YES														
20	7.4	41	N/A	N/A	YES														
21	7.4	38	N/A	N/A	YES														
22	7.3	41	N/A	N/A	YES														
23	7.3	40	N/A	N/A	YES														
24	7.3	40	N/A	N/A	YES														
25	7.4	40	N/A	N/A	YES														
26	7.4	40	N/A	N/A	YES														
27	7.4	40	N/A	N/A	YES														
28	7.7	39	N/A	N/A	YES														
29	7.7	40	N/A	N/A	YES														
30	7.5	40	N/A	N/A	YES														
31	N/A	N/A	N/A	N/A	N/A														
Total N's																			

(No=N=Excursion)

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone:(971) 673-0405

Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>