Or	Oregon Department					Water Quality Parameter Monitoring Form		
of	Human Servic	es			Lead & C	opper Rule C	orrosion Conti	rol
Day	pН	Alk	Phos	Sili	Y/N	< <have< th=""><th>County: Lane</th><th>Agency: REGION 2</th></have<>	County: Lane	Agency: REGION 2
1	7.3	38	N/A	N/A	YES	minimums		ENTRY POINT
2	7.3	38	N/A	N/A	YES	been met for		Entry Point: EP-B
3	7.3	36	N/A	N/A	YES	this day?		PWS ID 4100246B
4	7.4	40	N/A	N/A	YES		System Name:	Creswell, City of
5	7.4	40	N/A	N/A	YES		Sample period:	January-24
6	7.4	40	N/A	N/A	YES		Campie periou.	Month/year
7	7.4	40	N/A	N/A	YES		L	Monthyyear
8	7.4	40	N/A	N/A	YES		Number of exc	ursions during this month: $0$
9	7.3	39	N/A	N/A	YES		(Over 9 excursions in 6 months is a violation.	
10	7.3	39	N/A	N/A	YES		Entry Point and Distribution excursions are	
11	7.4	40	N/A	N/A	YES		cumulative). An 'excursion' is any day in which the	
12	7.4	40	N/A	N/A	YES		water quality parameter(s) fall below the minimun	
13	7.4	40	N/A	N/A	YES		set by the State.	
14	7.4	40	N/A	N/A	YES		-	
15	7.4	40	N/A	N/A	YES			
16	7.3	37	N/A	N/A	YES			
17	7.3	37	N/A	N/A	YES		Reference: Minir	mun pH set on 11/3/2003 By John Potts.
18	7.3	37	N/A	N/A	YES			
19	7.4	39	N/A	N/A	YES		Minimum Wate	
20	7.4	39	N/A	N/A	YES		Parameter(s) as	s set by State:
21	7.5	40	N/A	N/A	YES			_
22	7.5	40	N/A	N/A	YES		pH 7.1	
23	7.4	44	N/A	N/A	YES		Alk 33	(Alkalinity)
24	7.4	42	N/A	N/A	YES		PO4 N/A	(Orthophosphate)
25	7.4	40	N/A	N/A	YES		Sili N/A	(Silicate)
26	7.4	40	N/A	N/A	YES		Drint Norses	Mike Howard
27	7.4	40	N/A	N/A	YES		Print Name:	Mike Howard
28	7.5	42	N/A	N/A	YES			
29	7.5	42	N/A	N/A	YES		Signature:	
30	7.4	40	N/A	N/A	YES			541-736-6015
31	7.4	35	N/A	N/A	YES		2/1/202	4
=Excursion) Total N's						Send to DWP	within 10 days after ei	nd of sampling period
					DHS, Drinking	Water Program, Po	O Box 14350, Portlan	d, OR 97293-0350