

)('

DHS
Oregon Department
of Human Services

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2 ENTRY POINT Entry Point: EP-B PWS ID 4100246B System Name: <u>Creswell, City of</u> Sample period: <u>February-24</u> Month/year								
1	7.4	40	N/A	N/A	YES		<p>Number of excursions during this month: <u>0</u> (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.</p> <p>Reference: Minimum pH set on 11/3/2003 By John Potts.</p> <div> <p>Minimum Water Quality Parameter(s) as set by State:</p> <table border="1"> <tr><td>pH</td><td>7.1</td></tr> <tr><td>Alk</td><td>33 (Alkalinity)</td></tr> <tr><td>PO4</td><td>N/A (Orthophosphate)</td></tr> <tr><td>Sili</td><td>N/A (Silicate)</td></tr> </table> </div> <p>Print Name: Mike Howard</p> <p>Signature: Mike Howard</p> <p>541-736-6015</p> <p>3/1/2024</p>	pH	7.1	Alk	33 (Alkalinity)	PO4	N/A (Orthophosphate)	Sili	N/A (Silicate)
pH	7.1														
Alk	33 (Alkalinity)														
PO4	N/A (Orthophosphate)														
Sili	N/A (Silicate)														
2	7.4	40	N/A	N/A	YES										
3	7.4	40	N/A	N/A	YES										
4	7.4	40	N/A	N/A	YES										
5	7.5	40	N/A	N/A	YES										
6	7.4	38	N/A	N/A	YES										
7	7.7	36	N/A	N/A	YES										
8	7.7	38	N/A	N/A	YES										
9	7.6	40	N/A	N/A	YES										
10	7.6	40	N/A	N/A	YES										
11	7.5	40	N/A	N/A	YES										
12	7.5	40	N/A	N/A	YES										
13	7.4	38	N/A	N/A	YES										
14	7.4	38	N/A	N/A	YES										
15	7.4	38	N/A	N/A	YES										
16	7.4	38	N/A	N/A	YES										
17	7.4	40	N/A	N/A	YES										
18	7.4	40	N/A	N/A	YES										
19	7.5	40	N/A	N/A	YES										
20	7.3	36	N/A	N/A	YES										
21	7.3	40	N/A	N/A	YES										
22	7.3	38	N/A	N/A	YES										
23	7.4	40	N/A	N/A	YES										
24	7.4	40	N/A	N/A	YES										
25	7.4	40	N/A	N/A	YES										
26	7.4	40	N/A	N/A	YES										
27	7.3	42	N/A	N/A	YES										
28	7.3	44	N/A	N/A	YES										
29	7.4	38	N/A	N/A	YES										
30	N/A	N/A	N/A	N/A	N/A										
31	N/A	N/A	N/A	N/A	N/A										
(No=N=Excursion)					Total N's		Send to DWP within 10 days after end of sampling period								

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone:(971) 673-0405 Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>