

)'

DHS
Oregon Department
of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4	40	N/A	N/A	YES
2	7.4	40	N/A	N/A	YES
3	7.4	40	N/A	N/A	YES
4	7.4	40	N/A	N/A	YES
5	7.3	38	N/A	N/A	YES
6	7.4	40	N/A	N/A	YES
7	7.4	40	N/A	N/A	YES
8	7.5	40	N/A	N/A	YES
9	7.5	40	N/A	N/A	YES
10	7.5	40	N/A	N/A	YES
11	7.5	40	N/A	N/A	YES
12	7.5	40	N/A	N/A	YES
13	7.6	40	N/A	N/A	YES
14	7.6	40	N/A	N/A	YES
15	7.6	40	N/A	N/A	YES
16	7.6	40	N/A	N/A	YES
17	7.6	40	N/A	N/A	YES
18	7.6	40	N/A	N/A	YES
19	7.5	42	N/A	N/A	YES
20	7.5	42	N/A	N/A	YES
21	7.5	40	N/A	N/A	YES
22	7.5	40	N/A	N/A	YES
23	7.5	40	N/A	N/A	YES
24	7.5	40	N/A	N/A	YES
25	7.5	40	N/A	N/A	YES
26	7.7	39	N/A	N/A	YES
27	7.7	40	N/A	N/A	YES
28	7.6	42	N/A	N/A	YES
29	7.5	40	N/A	N/A	YES
30	7.5	40	N/A	N/A	YES
31	7.5	40	N/A	N/A	YES

<<Have
minimums
been met for
this day?

County: Lane Agency: REGION 2
ENTRY POINT
 Entry Point: EP-B
 PWS ID 4100246B
 System Name: Creswell, City of
 Sample period: March-24
 Month/year

Number of excursions during this month: 0
*(Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 cumulative). An 'excursion' is any day in which the
 water quality parameter(s) fall below the minimum
 set by the State.*

Reference: Minimum pH set on 11/3/2003 By John Potts.

Minimum Water Quality Parameter(s) as set by State:	
pH	7.1
Alk	33 (Alkalinity)
PO4	N/A (Orthophosphate)
Sili	N/A (Silicate)

Print Name: Mike Howard

Signature: Mike Howard

541-736-6015
4/1/2024

(No=N=Excursion) **Total N's** Send to DWP within 10 days after end of sampling period