

)('

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2 ENTRY POINT Entry Point: EP-B PWS ID 4100246B System Name: <u>Creswell, City of</u> Sample period: <u>June-24</u> Month/year
1	7.5	40	N/A	N/A	YES		
2	7.5	40	N/A	N/A	YES		
3	7.5	40	N/A	N/A	YES		
4	7.5	38	N/A	N/A	YES		
5	7.4	38	N/A	N/A	YES		
6	7.3	40	N/A	N/A	YES		
7	7.4	40	N/A	N/A	YES		
8	7.4	42	N/A	N/A	YES		
9	7.4	42	N/A	N/A	YES		
10	7.4	40	N/A	N/A	YES		
11	7.4	39	N/A	N/A	YES		
12	7.4	40	N/A	N/A	YES		
13	7.4	40	N/A	N/A	YES		
14	7.4	40	N/A	N/A	YES		
15	7.4	40	N/A	N/A	YES		
16	7.4	40	N/A	N/A	YES		
17	7.4	44	N/A	N/A	YES		
18	7.4	40	N/A	N/A	YES		
19	7.5	42	N/A	N/A	YES		
20	7.4	40	N/A	N/A	YES		
21	7.4	40	N/A	N/A	YES		
22	7.4	40	N/A	N/A	YES		
23	7.5	40	N/A	N/A	YES		
24	7.5	40	N/A	N/A	YES		
25	7.4	38	N/A	N/A	YES		
26	7.5	36	N/A	N/A	YES		
27	7.5	38	N/A	N/A	YES		
28	7.5	40	N/A	N/A	YES		
29	7.5	40	N/A	N/A	YES		
30	7.5	40	N/A	N/A	YES		
31	N/A	N/A	N/A	N/A	N/A		

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference: Minimum pH set on 11/3/2003 By John Potts.

Minimum Water Quality	
Parameter(s) as set by State:	
pH	7.1
Alk	33 (Alkalinity)
PO4	N/A (Orthophosphate)
Sili	N/A (Silicate)

Print Name: Mike Howard

Signature: Mike Howard

541-736-6015

7/1/2024

(No=N=Excursion)

Total N's

Send to DWP within 10 days after end of sampling period