)'(DHS						
/ (Oregon Department					Water Quality Para	ameter Monitoring Form
	of Human Services				Lead & Copper Rule Corrosion Control		
	or Human Octvices				Loud d O		
Day	рН	Alk	Phos	Sili	Y/N	< <have< th=""><th>County: Lane Agency: REGION 2</th></have<>	County: Lane Agency: REGION 2
1	7.4	40	N/A	N/A	YES	minimums	ENTRY POINT
2	7.5	44	N/A	N/A	YES	been met for	Entry Point: EP-B
3	7.6	40	N/A	N/A	YES	this day?	PWS ID 4100246B
4	7.6	42	N/A	N/A	YES		System Name: Creswell, City of
5	7.6	42	N/A	N/A	YES		Sample period: September-24
6	7.5	40	N/A	N/A	YES		Month/year
7	7.5	42	N/A	N/A	YES		
8	7.5	42	N/A	N/A	YES		Number of excursions during this month: <u>0</u>
9	7.8	37	N/A	N/A	YES		(Over 9 excursions in 6 months is a violation.
10	7.7	40	N/A	N/A	YES		Entry Point and Distribution excursions are
11	7.6	40	N/A	N/A	YES		cumulative). An 'excursion' is any day in which the
12	7.6	40	N/A	N/A	YES		water quality parameter(s) fall below the minimun
13	7.5	40	N/A	N/A	YES		set by the State.
14	7.5	40	N/A	N/A	YES		
15	7.5	40	N/A	N/A	YES		
16	7.5	40	N/A	N/A	YES		
17	7.5	38	N/A	N/A	YES		Reference: Minimun pH set on 11/3/2003 By John Potts.
18	7.4	40	N/A	N/A	YES		
19	7.4	42	N/A	N/A	YES		Minimum Water Quality
20	7.4	40	N/A	N/A	YES		Parameter(s) as set by State:
21	7.5	40	N/A	N/A	YES		
22	7.5	40	N/A	N/A	YES		pH 7.1
23	7.4	42	N/A	N/A	YES		Alk 33 (Alkalinity)
24	7.4	40	N/A	N/A	YES		PO4 N/A (Orthophosphate)
25	7.4	40	N/A	N/A	YES		Sili N/A (Silicate)
26	7.4	40	N/A	N/A	YES		B. (Marco Mile Harrison
27	7.5	40	N/A	N/A	YES		Print Name: Mike Howard
28	7.5	40	N/A	N/A	YES		
29	7.5	40	N/A	N/A	YES		Signature: Mike Howard
30	7.5	40	N/A	N/A	YES		541-736-6015
31	N/A	N/A	N/A	N/A	N/A		10/3/02024
No=N=Excursion) Total N's						Send to DWP w	ithin 10 days after end of sampling period
					DHS, Drinking	Water Program, PO	Box 14350, Portland, OR 97293-0350
					Phone:(971) 6		Website: http://oregon.gov/DHS/ph/dwp/index.shtml
					. , , , ,		