

)('

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane      Agency: REGION 2  <b>ENTRY POINT</b> Entry Point: EP-B <b>PWS ID 4100246B</b> System Name: <u>Creswell, City of</u> Sample period: <u>November-24</u> Month/year
1	7.5	40	N/A	N/A	YES		
2	7.5	40	N/A	N/A	YES		
3	7.5	40	N/A	N/A	YES		
4	7.5	40	N/A	N/A	YES		
5	7.3	44	N/A	N/A	YES		
6	7.3	44	N/A	N/A	YES		
7	7.3	42	N/A	N/A	YES		
8	7.3	42	N/A	N/A	YES		
9	7.4	42	N/A	N/A	YES		
10	7.4	40	N/A	N/A	YES		
11	7.9	44	N/A	N/A	YES		
12	7.6	43	N/A	N/A	YES		
13	7.7	40	N/A	N/A	YES		
14	7.7	42	N/A	N/A	YES		
15	7.7	44	N/A	N/A	YES		
16	7.7	44	N/A	N/A	YES		
17	7.6	42	N/A	N/A	YES		
18	7.5	40	N/A	N/A	YES		
19	7.7	38	N/A	N/A	YES		
20	7.7	38	N/A	N/A	YES		
21	7.7	38	N/A	N/A	YES		
22	7.7	38	N/A	N/A	YES		
23	7.7	40	N/A	N/A	YES		
24	7.7	40	N/A	N/A	YES		
25	7.7	40	N/A	N/A	YES		
26	7.5	38	N/A	N/A	YES		
27	7.5	38	N/A	N/A	YES		
28	7.8	40	N/A	N/A	YES		
29	7.7	40	N/A	N/A	YES		
30	7.7	40	N/A	N/A	YES		
31	N/A	N/A	N/A	N/A	N/A		
(No=N=Excursion)					Total N's		Send to DWP within 10 days after end of sampling period

Number of excursions during this month: 0  
(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

Reference: Minimum pH set on 11/3/2003 By John Potts.

**Minimum Water Quality  
Parameter(s) as set by State:**

pH	7.1	
Alk	33	(Alkalinity)
PO4	N/A	(Orthophosphate)
Sili	N/A	(Silicate)

**Print Name: Mike Howard**

**Signature: Mike Howard**

**541-736-6015**

**12/1/2024**