

) (

DHS

Oregon Department
of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2
1	7.5	40	N/A	N/A	YES		ENTRY POINT Entry Point: EP-B PWS ID 4100246B
2	7.5	40	N/A	N/A	YES		
3	7.4	38	N/A	N/A	YES		
4	7.4	38	N/A	N/A	YES		System Name: Creswell, City of
5	7.4	38	N/A	N/A	YES		Sample period: February 2025
6	7.5	38	N/A	N/A	YES		Month/year
7	7.5	40	N/A	N/A	YES		
8	7.5	40	N/A	N/A	YES		
9	7.5	40	N/A	N/A	YES		
10	7.5	40	N/A	N/A	YES		
11	7.6	38	N/A	N/A	YES		
12	7.6	38	N/A	N/A	YES		
13	7.6	40	N/A	N/A	YES		
14	7.6	40	N/A	N/A	YES		
15	7.6	42	N/A	N/A	YES		
16	7.6	40	N/A	N/A	YES		
17	7.5	38	N/A	N/A	YES		
18	7.5	38	N/A	N/A	YES		
19	7.5	38	N/A	N/A	YES		
20	7.4	38	N/A	N/A	YES		
21	7.4	38	N/A	N/A	YES		
22	7.4	38	N/A	N/A	YES		
23	7.4	38	N/A	N/A	YES		
24	7.5	38	N/A	N/A	YES		
25	7.5	38	N/A	N/A	YES		
26	7.5	38	N/A	N/A	YES		
27	7.5	40	N/A	N/A	YES		
28	7.5	40	N/A	N/A	YES		
29	N/A	N/A	N/A	N/A	N/A		
30	N/A	N/A	N/A	N/A	N/A		
31	N/A	N/A	N/A	N/A	N/A		
(No=N=Excursion) Total N's							Send to DWP within 10 days after end of sampling period

Minimum Water Quality
Parameter(s) as set by State:

pH	7.1	
Alk	33	(Alkalinity)
PO4	N/A	(Orthophosphate)
Sili	N/A	(Silicate)

Print Name: **Mike Howard**

Signature: *Mike Howard*

541-736-6015
3/1/2025

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>