

DHS

Oregon Department
of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Creswell, City of						County: Lane Agency: REGION 2	
Day	pH	Alk	Phos	Sili	Y/N	<<Have	
1	7.5	40	N/A	N/A	YES	minimums	ENTRY POINT Entry Point: EP-B PWS ID 4100246B
2	7.5	40	N/A	N/A	YES	been met for	
3	7.5	40	N/A	N/A	YES	this day?	
4	7.4	40	N/A	N/A	YES		System Name: Creswell, City of
5	7.5	38	N/A	N/A	YES		Sample period: March-25
6	7.5	42	N/A	N/A	YES		Month/year
7	7.5	38	N/A	N/A	YES		
8	7.5	38	N/A	N/A	YES		
9	7.8	34	N/A	N/A	YES		Number of excursions during this month: 0
10	7.7	34	N/A	N/A	YES		<i>(Over 9 excursions in 6 months is a violation.</i>
11	7.6	34	N/A	N/A	YES		<i>Entry Point and Distribution excursions are</i>
12	7.6	34	N/A	N/A	YES		<i>cumulative). An 'excursion' is any day in which the</i>
13	7.8	36	N/A	N/A	YES		<i>water quality parameter(s) fall below the minimum</i>
14	7.8	35	N/A	N/A	YES		<i>set by the State.</i>
15	7.8	35	N/A	N/A	YES		
16	7.5	35	N/A	N/A	YES		
17	7.7	34	N/A	N/A	YES		
18	7.7	34	N/A	N/A	YES		
19	7.7	35	N/A	N/A	YES		
20	7.7	37	N/A	N/A	YES		
21	7.8	37	N/A	N/A	YES		
22	7.8	37	N/A	N/A	YES		
23	8.0	34	N/A	N/A	YES		
24	7.8	34	N/A	N/A	YES		
25	8.0	34	N/A	N/A	YES		
26	8.0	34	N/A	N/A	YES		
27	7.8	34	N/A	N/A	YES		
28	7.8	34	N/A	N/A	YES		
29	8.0	36	N/A	N/A	YES		
30	7.9	35	N/A	N/A	YES		
31	7.8	35	N/A	N/A	YES		

Minimum Water Quality
Parameter(s) as set by State:

pH	7.1	
Alk	33	(Alkalinity)
PO4	N/A	(Orthophosphate)
Sili	N/A	(Silicate)

Print Name: Mike Howard

Signature: Mike Howard

4/3/2025

541-736-6015

(No=N=Excursion)

Total N's

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone:(971) 673-0405

Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>