

) (

DHS

Oregon Department
of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2 ENTRY POINT Entry Point: EP-B PWS ID 4100246B System Name: Creswell, City of Sample period: April-25 Month/year								
1	7.3	34	N/A	N/A	YES		<p>Number of excursions during this month: <u>0</u></p> <p>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.</p> <div> <p>Minimum Water Quality Parameter(s) as set by State:</p> <table border="1"> <tr><td>pH</td><td>7.1</td></tr> <tr><td>Alk</td><td>33</td></tr> <tr><td>PO4</td><td>N/A</td></tr> <tr><td>Sili</td><td>N/A</td></tr> </table> <p>(Alkalinity) (Orthophosphate) (Silicate)</p> </div> <p>Print Name: Mike Howard</p> <p>Signature: <i>Mike Howard</i></p> <p style="text-align: right;">541-736-6015</p> <p style="text-align: center;">5/1/2025</p>	pH	7.1	Alk	33	PO4	N/A	Sili	N/A
pH	7.1														
Alk	33														
PO4	N/A														
Sili	N/A														
2	7.4	34	N/A	N/A	YES										
3	7.5	36	N/A	N/A	YES										
4	7.9	34	N/A	N/A	YES										
5	8.0	34	N/A	N/A	YES										
6	8.0	34	N/A	N/A	YES										
7	8.0	36	N/A	N/A	YES										
8	8.3	34	N/A	N/A	YES										
9	8.0	35	N/A	N/A	YES										
10	8.1	38	N/A	N/A	YES										
11	8.0	40	N/A	N/A	YES										
12	8.0	34	N/A	N/A	YES										
13	8.1	34	N/A	N/A	YES										
14	8.1	34	N/A	N/A	YES										
15	8.2	36	N/A	N/A	YES										
16	8.4	38	N/A	N/A	YES										
17	8.2	35	N/A	N/A	YES										
18	8.0	35	N/A	N/A	YES										
19	8.0	33	N/A	N/A	YES										
20	8.0	35	N/A	N/A	YES										
21	8.0	36	N/A	N/A	YES										
22	8.1	36	N/A	N/A	YES										
23	8.0	40	N/A	N/A	YES										
24	7.9	36	N/A	N/A	YES										
25	7.8	39	N/A	N/A	YES										
26	7.9	37	N/A	N/A	YES										
27	7.9	36	N/A	N/A	YES										
28	8.0	38	N/A	N/A	YES										
29	7.9	36	N/A	N/A	YES										
30	8.0	38	N/A	N/A	YES										
31	N/A	N/A	N/A	N/A	N/A										
(No=N=Excursion) Total N's							Send to DWP within 10 days after end of sampling period								

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone:(971) 673-0405

Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>