

DHS Oregon Department of Human Services Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control						County: Lane Agency: REGION 2 ENTRY POINT Entry Point: EP-B PWS ID 4100246B System Name: <u>Creswell, City of</u> Sample period: <u>August-25</u> Month/year												
Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?												
1	7.8	44	N/A	N/A			Number of excursions during this month: <u> 0 </u> <i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.</i> Minimum Water Quality Parameter(s) as set by State: <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="border: 1px solid black; padding: 2px;">pH</td> <td style="border: 1px solid black; padding: 2px;">7.1</td> <td rowspan="2" style="padding-left: 10px;">(Alkalinity)</td> </tr> <tr> <td style="border: 1px solid black; padding: 2px;">Alk</td> <td style="border: 1px solid black; padding: 2px;">33</td> </tr> <tr> <td style="border: 1px solid black; padding: 2px;">PO4</td> <td style="border: 1px solid black; padding: 2px;">N/A</td> <td>(Orthophosphate)</td> </tr> <tr> <td style="border: 1px solid black; padding: 2px;">Sili</td> <td style="border: 1px solid black; padding: 2px;">N/A</td> <td>(Silicate)</td> </tr> </table> Print Name: Sam Haynes Signature: Sam Haynes 541-517-4761 8/1/2025	pH	7.1	(Alkalinity)	Alk	33	PO4	N/A	(Orthophosphate)	Sili	N/A	(Silicate)
pH	7.1	(Alkalinity)																
Alk	33																	
PO4	N/A	(Orthophosphate)																
Sili	N/A	(Silicate)																
2	7.8	41	N/A	N/A														
3	7.9	42	N/A	N/A														
4	8.0	41	N/A	N/A														
5	8.1	38	N/A	N/A														
6	8.1	43	N/A	N/A														
7	7.9	39	N/A	N/A														
8	8.0	40	N/A	N/A														
9	7.9	38	N/A	N/A														
10	7.9	42	N/A	N/A														
11	8.1	38	N/A	N/A														
12	8.0	40	N/A	N/A														
13	7.8	36	N/A	N/A														
14	8.1	41	N/A	N/A														
15	7.8	41	N/A	N/A														
16	8.0	39	N/A	N/A														
17	8.0	42	N/A	N/A														
18	8.1	40	N/A	N/A														
19	7.9	36	N/A	N/A														
20	8.0	40	N/A	N/A														
21	8.1	40	N/A	N/A														
22	8.0	42	N/A	N/A														
23	8.1	41	N/A	N/A														
24	7.9	44	N/A	N/A														
25	8.1	42	N/A	N/A														
26	7.9	40	N/A	N/A														
27	7.9	44	N/A	N/A														
28	8.1	47	N/A	N/A														
29	8.1	44	N/A	N/A														
30	8.1	45	N/A	N/A														
31	8.0	44	N/A	N/A														
(No=N=Excursion) Total N's						Send to DWP within 10 days after end of sampling period												
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone: (971) 673-0405 Website: http://oregon.gov/DHS/ph/dwp/index.shtml																		