

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.40		1.65		Y
2	7.56	43.0	1.69		Y
3	7.44		1.38		Y
4	7.40		1.40		Y
5	7.38		1.46		Y
6	7.58		1.38		Y
7	7.59		1.63		Y
8	7.59		1.61		Y
9	7.39		1.58		Y
10	7.42		1.45		Y
11	7.35		1.48		Y
12	7.36		1.51		Y
13	7.41		1.60		Y
14	7.34		1.61		Y
15	7.35		1.59		Y
16	7.54	41.8	1.61		Y
17	7.29		1.53		Y
18	7.35		1.53		Y
19	7.41		1.55		Y
20	7.35		1.53		Y
21	7.36		1.69		Y
22	7.38		1.65		Y
23	7.45		1.74		Y
24	7.55		1.78		Y
25	7.40		1.71		Y
26	7.49		1.71		Y
27	7.57		1.84		Y
28	7.62		1.68		Y
29	7.60	48.1	1.65		Y
30	7.54		1.71		Y
31	7.62		1.77		Y

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: May 2024  
Month/Year

Number of excursions during this month: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson  
Signature: [Signature]  
Date & Phone#: 5/4/24 503-623-2175

Send to DWP within 10 days after end of sampling period