

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.53		1.55		Y
2	7.59	40.2	1.74		Y
3	7.57		1.62		Y
4	7.38		1.89		Y
5	7.44		1.77		Y
6	7.41		1.81		Y
7	7.45		1.77		Y
8	7.46		1.57		Y
9	7.24	39.9	1.67		Y
10	7.41		1.86		Y
11	7.42	37.1	1.78		Y
12	7.44	38.4	1.75		Y
13	7.74	38.2	1.75		Y
14	7.86		1.71		Y
15	7.78		1.68		Y
16	8.03	41.8	1.71		Y
17	8.04		1.62		Y
18	7.87		1.80		Y
19	7.39		1.63		Y
20	7.38		1.65		Y
21	7.37		1.70		Y
22	7.33		1.64		Y
23	7.43		1.68		Y
24	7.44		1.69		Y
25	7.52	39.6	1.59		Y
26	7.46		1.86		Y
27	7.56		1.76		Y
28	7.43		1.62		Y
29	7.41		1.68		Y
30	7.40		1.64		Y
31	7.45		1.61		Y

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: July 2024  
 Month/Year

**Number of excursions during this month:** \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

**Print Name:** Jason Anderson  
**Signature:** Jason Anderson  
**Date & Phone#:** 8/2/24 503-623-2175

Send to DWP within 10 days after end of sampling period