

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.58		1.60		Y
2	7.50	37.2	1.71		Y
3	7.63		1.89		Y
4	7.73		1.61		Y
5	7.65		1.59		Y
6	7.69	39.1	1.71		Y
7	7.32		1.71		Y
8	7.47		1.47		Y
9	7.58		1.84		Y
10	7.61		1.81		Y
11	7.54		1.74		Y
12	7.48		1.81		Y
13	7.41		1.57		Y
14	7.56		1.58		Y
15	7.32		1.94		Y
16	7.31		1.86		Y
17	7.49	36.7	1.78		Y
18	7.79		1.69		Y
19	7.81		1.65		Y
20	7.73		1.67		Y
21	7.55		1.79		Y
22	7.46		1.67		Y
23	7.60		1.82		Y
24	7.59	40.1	1.79		Y
25	7.56		1.64		Y
26	7.66		1.68		Y
27	7.26		1.55		Y
28	7.49		1.77		Y
29	7.50		1.70		Y
30	7.38		1.63		Y
31	7.49		1.59		Y

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Polk

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100248

DALLAS, CITY OF

Sample period: January 2025
Month/Year

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson

Signature: [Signature]

Date & Phone#: 2/3/25 503-623-2175

Send to DWP within 10 days after end of sampling period