

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.76		1.69		Y
2	7.45		1.56		Y
3	7.64	40.9	1.79		Y
4	7.42		1.64		Y
5	7.65		1.58		Y
6	7.74		1.58		Y
7	7.53		1.46		Y
8	7.52		1.67		Y
9	7.58		1.74		Y
10	7.43		1.57		Y
11	7.41		1.65		Y
12	7.54		1.66		Y
13	7.66	37.9	1.76		Y
14	7.38		1.66		Y
15	7.53		1.69		Y
16	7.51		1.52		Y
17	7.42		1.78		Y
18	7.46		1.72		Y
19	7.36		1.58		Y
20	7.29	36.7	1.82		Y
21	7.44		1.85		Y
22	7.62		1.63		Y
23	7.56		1.60		Y
24	7.47	34.5	1.84		Y
25	7.48		1.71		Y
26	7.50		1.69		Y
27	7.47		1.67		Y
28	7.53		1.56		Y
29					
30					
31					

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Polk

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100248

DALLAS, CITY OF

Sample period: Feb 2025
Month/Year

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson
Signature: Jason Anderson
Date & Phone#: 3/3/25 503-623-2175

Send to DWP within 10 days after end of sampling period