

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.74		1.67		Y
2	7.71		1.41		Y
3	7.49		1.78		Y
4	7.58		1.71		Y
5	7.53		1.54		Y
6	7.55	38.6	1.57		Y
7	7.68		1.46		Y
8	7.60		1.65		Y
9	7.71		1.53		Y
10	7.47		1.67		Y
11	7.60		1.71		Y
12	7.64		1.66		Y
13	7.63		1.61		Y
14	7.66		1.64		Y
15	7.90		1.62		Y
16	7.79		1.51		Y
17	7.56		1.50		Y
18	7.57		1.80		Y
19	7.65		1.55		Y
20	7.53	38.0	1.55		Y
21	7.69		1.64		Y
22	7.49		1.61		Y
23	7.43		1.65		Y
24	7.43		1.88		Y
25	7.48		1.80		Y
26	7.57		1.48		Y
27	7.51		1.71		Y
28	7.54		1.84		Y
29	7.90		1.62		Y
30	7.67		1.63		Y
31	7.57		1.62		Y

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Polk Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100248

DALLAS, CITY OF

Sample period: March 2025
Month/Year

Number of excursions during this month: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson
Signature: Jason Anderson
Date & Phone#: 4/1/25 503-623-2175

Send to DWP within 10 days after end of sampling period