

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.49		1.84		Y
2	7.61		1.65		Y
3	7.55	38.1	1.60		Y
4	7.67		1.71		Y
5	7.55		1.86		Y
6	7.51		1.77		Y
7	7.52		2.01		Y
8	7.47		1.58		Y
9	7.54		1.85		Y
10	7.64		1.67		Y
11	7.76		1.57		Y
12	7.72		1.62		Y
13	7.48		1.73		Y
14	7.47		1.46		Y
15	7.68		1.61		Y
16	7.68		1.77		Y
17	7.71	38.2	1.88		Y
18	7.65		1.72		Y
19	7.75		1.57		Y
20	7.86		1.80		Y
21	7.73		1.80		Y
22	7.64		1.71		Y
23	7.65		1.80		Y
24	7.64		1.78		Y
25	7.64		1.69		Y
26	7.87		1.59		Y
27	8.17		1.68		Y
28	7.53		1.53		Y
29	7.61		1.60		Y
30	7.58		1.80		Y
31					

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Polk

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100248

DALLAS, CITY OF

Sample period: April 2025
Month/Year

Number of excursions during this month: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson

Signature: Jason Anderson

Date & Phone#: 5/1/2025

Send to DWP within 10 days after end of sampling period