

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.63	40.4	1.55		Y
2	7.61		1.65		Y
3	7.55		1.58		Y
4	7.57		1.65		Y
5	7.52		1.62		Y
6	7.49		1.72		Y
7	7.51		1.77		Y
8	7.56		1.89		Y
9	7.61		1.61		Y
10	7.75		1.80		Y
11	7.81		1.82		Y
12	7.61		1.88		Y
13	7.67		1.78		Y
14	7.62		1.93		Y
15	7.61	44.4	1.88		Y
16	7.62		1.97		Y
17	7.73		1.73		Y
18	7.76		1.70		Y
19	7.61		1.68		Y
20	7.64		1.85		Y
21	7.75		1.80		Y
22	7.62		1.58		Y
23	7.63		1.62		Y
24	7.68		1.52		Y
25	7.59		1.87		Y
26	7.65		1.68		Y
27	7.58		1.65		Y
28	7.55	42.1	1.78		Y
29	7.61		1.83		Y
30	7.53		1.56		Y
31	7.65		1.70		Y

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Polk

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100248

DALLAS, CITY OF

Sample period: May 2025
Month/Year

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson

Signature: Jason Anderson

Date & Phone#: 6/3/25 503-623-2125

Send to DWP within 10 days after end of sampling period