

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.66		1.78		Y
2	7.63		1.70		Y
3	7.70		1.70		Y
4	7.63		1.70		Y
5	7.74	48.2	2.11		Y
6	7.74		1.91		Y
7	7.76		1.72		Y
8	7.43		1.47		Y
9	7.55		1.83		Y
10	7.53	42.9	1.62		Y
11	7.29	41.4	1.92		Y
12	7.39	41.6	1.61		Y
13	7.44		1.61		Y
14	7.51		1.90		Y
15	7.54		2.08		Y
16	7.51		1.75		Y
17	7.51		1.86		Y
18	7.53	43.2	1.92		Y
19	7.54		1.90		Y
20	7.46		1.63		Y
21	7.68		1.70		Y
22	7.52		1.61		Y
23	7.42		1.71		Y
24	7.49		1.76		Y
25	7.45		1.86		Y
26	7.46		2.05		Y
27	7.46		2.10		Y
28	7.46		1.65		Y
29	7.55		1.95		Y
30	7.41		1.74		Y
31					

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Polk

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100248

DALLAS, CITY OF

Sample period: June 2025
Month/Year

Number of excursions during this month:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson

Signature: Jason Anderson

Date & Phone#: 7/1/25

Send to DWP within 10 days after end of sampling period