

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.54		1.88		✓
2	7.51	41.8	1.75		✓
3	7.46		1.92		✓
4	7.59		1.53		✓
5	7.42		1.55		✓
6	7.43		1.68		✓
7	7.43		1.86		✓
8	7.47		1.82		✓
9	7.43		1.83		✓
10	7.52		1.66		✓
11	7.50		1.62		✓
12	7.51		1.81		✓
13	7.51		1.79		✓
14	7.56	42.8	1.81		✓
15	7.49		1.78		✓
16	7.43		1.67		✓
17	7.40		1.58		✓
18	7.53		1.82		✓
19	7.46		1.98		✓
20	7.44		1.53		✓
21	7.50		1.57		✓
22	7.57		1.88		✓
23	7.52		1.80		✓
24	7.57	44.2	1.65		✓
25	7.44		2.00		✓
26	7.51		2.01		✓
27	7.61		1.64		✓
28	7.43		1.86		✓
29	7.53		1.84		✓
30	7.52		1.89		✓
31	7.54		1.95		✓

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Polk

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100248

DALLAS, CITY OF

Sample period: July 2025
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson
Signature: Jason Anderson
Date & Phone#: 8/4/25 503-623-2125

Send to DWP within 10 days after end of
sampling period