

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.46		1.59		✓
2	7.33	42.2	1.43		✓
3	7.50		1.69		✓
4	7.51		1.66		✓
5	7.51		1.51		✓
6	7.45		1.40		✓
7	7.44		1.38		✓
8	7.34		1.40		✓
9	7.47	49.2	1.51		✓
10	7.53		1.50		✓
11	7.52		1.59		✓
12	7.55		1.59		✓
13	7.41		1.50		✓
14	7.56		1.73		✓
15	7.47		1.57		✓
16	7.54	46.4	1.75		✓
17	7.48		1.44		✓
18	7.59		1.39		✓
19	7.51		1.50		✓
20	7.53		1.46		✓
21	7.47		1.59		✓
22	7.43		1.52		✓
23	7.49		1.52		✓
24	7.43		1.60		✓
25	7.43		1.54		✓
26	7.30		1.53		✓
27	7.23		1.59		✓
28	7.45		1.50		✓
29	7.44	45.2	1.60		✓
30	7.53		1.78		✓
31	7.60		1.88		✓

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

County: Polk

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100248

DALLAS, CITY OF

Sample period: October 2025
Month/Year

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

Alk 34.0 (Alkalinity)

PO4 1.3 (Orthophosphate)

Print Name: Jason Anderson

Signature: Jason Anderson

Date & Phone#: 11/3/25

Send to DWP within 10 days after end of sampling period