

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.61		1.80		Y
2	7.55		1.61		Y
3	7.47		1.79		Y
4	7.48		1.55		Y
5	7.44		1.59		Y
6	7.21		1.60		Y
7	7.60		1.74		Y
8	7.59		1.84		Y
9	7.39		1.52		Y
10	7.50		1.58		Y
11	7.71		1.58		Y
12	7.64		1.42		Y
13	7.53	34.6	1.62		Y
14	7.46	34.6	1.66		Y
15	7.47		1.79		Y
16	7.51		1.68		Y
17	7.48		1.94		Y
18	7.52		1.54		Y
19	7.64		2.04		Y
20	7.63	37.8	1.78		Y
21	7.62		1.75		Y
22	7.57		1.78		Y
23	7.52		1.78		Y
24	7.58		1.64		Y
25	7.80		1.67		Y
26	7.66		1.80		Y
27	7.56		1.54		Y
28	7.50		1.84		Y
29	7.51		1.50		Y
30	7.49		1.75		Y
31					

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Polk

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100248

DALLAS, CITY OF

Sample period: November 2025
Month/Year

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson

Signature: Jason Anderson

Date & Phone#: 12/2/25

Send to DWP within 10 days after end of
sampling period