

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID#	Sample Location	الما	Alle	DO4	Other	V/AI	1	
10 #	Sample Location	рН			Other	Y/N	Sample County: Polk Agency: REGION 1 Met the County: Polk Agency: REGION 1	
	6+51lobrahoud		43.7	-		7	minimum(s)? DISTRIBUTION	
	827 Ste Lyle	1	42,4	1		4		
	760 SUNATATE	7.42	43.1	1,38		4	PWS ID 4100248	
	6/05 EWALANT	7.32	42.4	1,43		Y	DALLAS, CITY OF	
	300 N.W. Derton	7.40	43.7	1,42		4	DALLAS, CITTOR	
	14265.E ANA	7,36	42,6	1,38		4	<u> </u>	
	2420 Maplewood	7,34	4213	1,39		4	Sample Period: Hugust 2021 Month/Year	
							Sample Frequency: Every 36 months	
-							Distribution Samples required: 7	
							Number of excursions during this Sample Period =	
							(Number of locations when any WQP was less than the minimum.)	
							Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.	
							Reference —	
							Minimum Water Quality Parameters as set by State:	
				,			pH 7.0 Alk 34.0 (Alkalinity)	
							PO4 1.3 (Orthophosphate)	
	(N = No = Exc	ursio	n) T	Print Name: Deuvis Schlegel Signature: Schlegel				
	0		_				Date: <u>\$\left\(\phi \left\(\left\) \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \</u>	
	Send to Drinking Water Program within 10 days after end of sampling period:							

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/

SEP 10 2021

Data Migmt & Compliance Drinking Water Program