

Day	pH	Alk	Phos	Other	Y/N
1	7.57		1.44		
2	7.57		1.38		
3	7.56		1.51		
4	7.53		1.46		
5	7.54		1.34		
6	7.50		1.35		
7	7.66	35.8	1.35		
8	7.21		1.35		
9	7.63		1.33		
10	7.63		1.43		
11	7.64		1.35		
12	7.79		1.56		
13	7.63		1.34		
14	8.03		1.65		
15					
16	7.57		1.51		
17	7.46		1.45		
18	7.28		1.38		
19	7.32		1.42		
20	7.61		1.46		
21	7.62	38.0	1.38		
22	7.62		1.34		
23	7.75		1.42		
24	7.80		1.34		
25	7.87	39.8	1.35		
26	7.81		1.46		
27	7.71		1.43		
28	7.80		1.61		
29	7.65		1.40		
30	7.66		1.36		
31	7.76		1.48		

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: Jan 2021  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlesel

Signature: [Signature]

Date & Phone#: 2/1/21 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's