

Day	pH	Alk	Phos	Other	Y/N
1	7.77		1.39		
2	7.77		1.35		
3	7.74		1.46		
4	7.70	34.3	1.40		
5	7.74		1.42		
6	7.65		1.40		
7	7.72		1.39		
8	7.74		1.42		
9	7.18		1.42		
10	7.79		1.36		
11	7.87		1.40		
12	7.83		1.37		
13	7.88		1.76		
14	7.25		1.95		
15	7.63		1.41		
16	7.61		1.35		
17	7.64	36.9	1.35		
18	7.83	38.9	1.47		
19	7.85		1.31		
20	7.70		1.37		
21	7.79		1.39		
22	7.90		1.50		
23	7.96		1.37		
24	7.92		1.43		
25	7.96		1.39		
26	7.90		1.41		
27	7.26		1.70		
28	7.24		1.56		
29					
30					
31					

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: Feb 2021  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlegel

Signature: [Signature]

Date & Phone#: 3/01/21 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's