

Day	pH	Alk	Phos	Other	Y/N
1	7.24		1.43		Y
2	7.33		1.46		Y
3	7.39	38.5	1.46		Y
4	7.43		1.47		Y
5	7.39	42.8	1.45		Y
6	7.36		1.43		Y
7	7.34		1.43		Y
8	7.32		1.40		Y
9	7.41		1.39		Y
10	7.40		1.36		Y
11	7.40		1.33		Y
12	7.40		1.43		Y
13	7.41		1.48		Y
14	7.42		1.41		Y
15	7.43		1.52		Y
16	7.39		1.43		Y
17	7.35		1.36		Y
18	7.43		1.41		Y
19	7.42	43.3	1.32		Y
20	7.43		1.38		Y
21	7.46		1.34		Y
22	7.49		1.35		Y
23	7.43		1.42		Y
24	7.46		1.41		Y
25	7.51		1.42		Y
26	7.41		1.37		Y
27	7.43		1.38		Y
28	7.43				
29	7.31		1.34		Y
30	7.39		1.42		Y
31	7.34		1.46		Y

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: Aug 2021  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jenna's Schlegel

Signature: [Signature]

Date & Phone#: 9/01/21 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**

9/28/21 Analyzer m/fal function

