

Day	pH	Alk	Phos	Other	Y/N
1	7.41		1.53		Y
2	7.38		1.41		Y
3	7.38		1.37		Y
4	7.44	50.1	1.55		Y
5	7.35		1.64		Y
6	7.46		1.53		Y
7	7.46	48.8	1.42		Y
8	7.42		1.37		Y
9	7.48		1.32		Y
10	7.44		1.56		Y
11	7.36		1.55		Y
12	7.50		1.54		Y
13	7.51		1.44		Y
14	7.50		1.49		Y
15	7.46		1.65		Y
16	7.45		1.52		Y
17	7.55		1.48		Y
18	7.40	47.5	1.68		Y
19	7.37		1.48		Y
20	7.39		1.50		Y
21	7.39	46.8	1.43		Y
22	7.37		1.60		Y
23	7.31		1.35		Y
24	7.22		1.42		Y
25	7.22		1.54		Y
26	7.28		1.44		Y
27	7.23		1.39		Y
28	7.16		1.42		Y
29	7.21	34.8	1.41		Y
30	7.27		1.73		Y
31	7.35		1.73		Y

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

ENTRY POINT

EP-A


PWS ID 4100248

DALLAS, CITY OF

Sample period: Oct. 2021
 Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.



Data Mgmt & Compliance
 Drinking Water Program

Reference

Minimum Water Quality Parameter(s) as set by State:

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlegel

Signature: DS

Date & Phone#: 11/01/21 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's