



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.30		1.52		Y
2	7.25		1.46		Y
3	7.24		1.51		Y
4	7.30	34.0	1.58		Y
5	7.31		1.44		Y
6	7.32		1.69		Y
7	7.34		1.90		Y
8	7.52		1.68		Y
9	7.47		1.44		Y
10	7.53		1.58		Y
11	7.52		1.39		Y
12	7.36		1.42		Y
13	7.35		1.41		Y
14	7.26		1.61		Y
15	7.17		1.61		Y
16	7.47		1.69		Y
17	7.46		1.45		Y
18	7.40	35.0	1.58		Y
19	7.45		1.46		Y
20	7.48		1.83		Y
21	7.19		2.00		Y
22	7.39		1.37		Y
23	7.32		1.70		Y
24	7.58		1.50		Y
25	7.58		1.42		Y
26	7.60		1.50		Y
27	7.55		1.51		Y
28	7.45		1.57		Y
29	7.50	34.8	1.52		Y
30	7.64		1.66		Y
31					

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: Nov 2021  
Month/Year

Number of excursions during this month: \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlegel

Signature: [Signature]

Date & Phone#: 12/01/21 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's