

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.50		1.57		Y
2	7.45		1.56		Y
3	7.43		1.58		Y
4	7.53		1.36		Y
5	7.52		1.59		Y
6	7.43	36.9	1.36		Y
7	7.57		1.42		Y
8	7.59		1.42		Y
9	7.55		1.32		Y
10	7.50		1.62		Y
11	7.60		1.40		Y
12	7.63		1.54		Y
13	7.62		1.65		Y
14	7.62		1.59		Y
15	7.51		1.53		Y
16	7.59		1.42		Y
17	7.56		1.63		Y
18	7.61	34.2	1.38		Y
19	7.71		1.59		Y
20	7.67		1.44		Y
21	7.77		1.40		Y
22	7.74		1.36		Y
23	8.02		1.33		Y
24	7.72		1.67		Y
25	7.59		1.69		Y
26	7.64		1.57		Y
27	7.74		1.66		Y
28	7.75	37.5	1.60		Y
29	7.66		1.37		Y
30	7.67		1.33		Y
31	7.70		1.58		Y

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: JAN 2012  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis L Schlegel  
Signature: [Signature]  
Date & Phone#: 2/01/22 503-623-2175

Send to DWP within 10 days after end of sampling period