



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.86		1.47		Y
2	7.86		1.50		Y
3	7.81	39	1.69		Y
4	7.71		1.43		Y
5	7.76		1.65		Y
6	7.82		1.44		Y
7	7.88		1.61		Y
8	7.81		1.57		Y
9	7.79		1.45		Y
10	7.76		1.39		Y
11	7.67		1.58		Y
12	7.88		1.33		Y
13	7.83		1.58		Y
14	7.69		1.56		Y
15	7.68	41.4	1.67		Y
16	7.84		1.65		Y
17	7.78		1.63		Y
18	7.88		1.49		Y
19	7.82		1.54		Y
20	7.84		1.60		Y
21	7.80		1.52		Y
22	7.66		1.54		Y
23	7.82	40.1	1.56		Y
24	7.86		1.63		Y
25	7.86		1.46		Y
26	7.73		1.41		Y
27	7.75		1.34		Y
28	7.63		1.46		Y
29					
30					
31					

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT
EP-A**

**PWS ID 4100248
DALLAS, CITY OF**

Sample period: Feb 2022
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlegel

Signature: [Signature]

Date & Phone#: 3/01/22 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's