



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.73		1.67		Y
2	7.54		1.59		Y
3	7.46	36.5	1.51		Y
4	7.58		1.42		Y
5	7.57		1.99		Y
6	7.61		1.63		Y
7	7.73		1.59		Y
8	7.65		1.47		Y
9	7.70		1.45		Y
10	7.71		1.55		Y
11	7.76		1.62		Y
12	7.63		1.44		Y
13	7.62		1.50		Y
14	7.57	36.2	1.63		Y
15	7.70		1.48		Y
16	7.67		1.39		Y
17	7.69		1.54		Y
18	7.82		1.54		Y
19	7.75		1.37		Y
20	7.73		1.47		Y
21	7.65		1.40		Y
22	7.60		1.33		Y
23	7.67		1.42		Y
24	7.64		1.62		Y
25	7.85	39.9	1.53		Y
26	7.83		1.51		Y
27	7.73		1.58		Y
28	7.75		1.50		Y
29	8.07		1.37		Y
30	7.92		1.69		Y
31	7.90		1.60		Y

(No = N = Excursion) **Total N's**


<<Have minimums been met for this day?

County: Polk Agency: REGION 1

ENTRY POINT
EP-A
PWS ID 4100248
DALLAS, CITY OF

Sample period: March 2022
Month/Year

Number of excursions during this month: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.



Reference Data Mgmt & Compliance
Drinking Water Program

Minimum Water Quality Parameter(s) as set by State:

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlegel
Signature:
Date & Phone#: 4/01/22 503-623-2175

Send to DWP within 10 days after end of sampling period