

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.95		1.42		Y
2	7.94	41.8	1.47		Y
3	7.80		1.40		Y
4	7.70		1.55		Y
5	7.60		1.64		Y
6	7.68		1.45		Y
7	7.81		1.45		Y
8	7.77		1.49		Y
9	7.71		1.42		Y
10	7.59		1.40		Y
11	7.49		1.45		Y
12	7.58		1.47		Y
13	7.60		1.40		Y
14	7.86	40.8	1.53		Y
15	7.82		1.46		Y
16	7.75		1.35		Y
17	7.59		1.47		Y
18	7.51		1.43		Y
19	7.51		1.61		Y
20	7.47		1.43		Y
21	7.86		1.37		Y
22	7.71		1.40		Y
23	7.67	41.0	1.49		Y
24	7.58		1.47		Y
25	7.62		1.56		Y
26	7.55		1.59		Y
27	7.45		1.32		Y
28	7.48		1.33		Y
29	7.51		1.42		Y
30	7.43		1.49		Y
31					

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**  
**EP-A**  
**PWS ID 4100248**  
**DALLAS, CITY OF**

Sample period: June 2022  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlegel  
 Signature: DS  
 Date & Phone#: 7/01/22 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's