

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.33		1.45		Y
2	7.48		1.43		Y
3	7.50		1.48		Y
4	7.51	38.7	1.49		Y
5	7.58		1.50		Y
6	7.55		1.33		Y
7	7.50		1.33		Y
8	7.51		1.51		Y
9	7.60		1.41		Y
10	7.55		1.31		Y
11	7.43		1.43		Y
12	7.47		1.39		Y
13	7.44		1.43		Y
14	7.47		1.38		Y
15	7.41		1.35		Y
16	7.43		1.44		Y
17	7.46	41.2	1.33		Y
18	7.50		1.33		Y
19	7.56		1.35		Y
20	7.47		1.40		Y
21	7.48		1.45		Y
22	7.47		1.43		Y
23	7.48		1.39		Y
24	7.55		1.42		Y
25	7.48		1.38		Y
26	7.48		1.42		Y
27	7.43		1.73		Y
28	7.43		1.58		Y
29	7.46		1.35		Y
30	7.43	42.6	1.44		Y
31	7.46		1.54		Y

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: Aug 2022  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

RECEIVED  
 SEP 07 2022

Reference: Data Mgmt & Compliance Drinking Water Program

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlegel

Signature: [Signature]

Date & Phone#: 9/01/22 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's