

| Day | pH | Alk | Phos | Other | Y/N |
|-----|------|------|------|-------|-----|
| 1 | 7.53 | | 1.37 | | Y |
| 2 | 7.48 | | 1.53 | | Y |
| 3 | 7.48 | | 1.33 | | Y |
| 4 | 7.56 | | 1.43 | | Y |
| 5 | 7.52 | | 1.42 | | Y |
| 6 | 7.41 | | 1.35 | | Y |
| 7 | 7.32 | | 1.45 | | Y |
| 8 | 7.06 | | 1.31 | | Y |
| 9 | 7.26 | 35.5 | 1.49 | | Y |
| 10 | 7.38 | | 1.45 | | Y |
| 11 | 7.29 | | 1.46 | | Y |
| 12 | 7.40 | | 1.48 | | Y |
| 13 | 7.50 | | 1.44 | | Y |
| 14 | 7.34 | | 1.39 | | Y |
| 15 | 7.25 | | 1.48 | | Y |
| 16 | 7.55 | | 1.45 | | Y |
| 17 | 7.41 | 37.9 | 1.60 | | Y |
| 18 | 7.48 | | 1.48 | | Y |
| 19 | 7.40 | | 1.36 | | Y |
| 20 | 7.54 | | 1.40 | | Y |
| 21 | 7.37 | | 1.58 | | Y |
| 22 | 7.28 | | 1.46 | | Y |
| 23 | 7.25 | | 1.43 | | Y |
| 24 | 7.37 | | 1.38 | | Y |
| 25 | 7.23 | | 1.42 | | Y |
| 26 | 7.12 | | 1.39 | | Y |
| 27 | 7.15 | | 1.43 | | Y |
| 28 | 7.21 | | 1.46 | | Y |
| 29 | 7.41 | 38.0 | 1.54 | | Y |
| 30 | 7.41 | | 1.35 | | Y |
| 31 | | | | | |

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100248

DALLAS, CITY OF

Sample period: NOV 2022
 Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

| | | |
|-----|------|------------------|
| pH | 7.0 | |
| Alk | 34.0 | (Alkalinity) |
| PO4 | 1.3 | (Orthophosphate) |

Print Name: Dennis Schlegel

Signature: [Signature]

Date & Phone#: 12/01/22 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's