

Day	pH	Alk	Phos	Other	Y/N
1	7.48		1.37		Y
2	7.37		1.43		Y
3	7.39		1.39		Y
4	7.35		1.41		Y
5	7.31		1.49		Y
6	7.48		1.45		Y
7	7.35		1.33		Y
8	7.27		1.45		Y
9	7.50	36.0	1.31		Y
10	7.45		1.38		N
11	7.67		1.36		Y
12	7.51		1.38		Y
13	7.30		1.45		Y
14	7.60		1.49		Y
15	7.62	38.4	1.47		Y
16	7.57		1.46		Y
17	7.43		1.50		Y
18	7.68		1.65		Y
19	7.48		1.51		Y
20	7.51		1.31		Y
21	7.55		1.42		Y
22	7.51		1.53		Y
23	7.61		1.44		Y
24	7.55		1.65		Y
25	7.59		1.43		Y
26	7.51		1.51		Y
27	7.57		1.50		Y
28	7.60	41.2	1.40		Y
29	7.61		1.43		Y
30	7.50		1.68		Y
31	7.53		1.44		Y

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

ENTRY POINT
EP-A
PWS ID 4100248
DALLAS, CITY OF

Sample period: Dec 2022
 Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlegel

Signature: [Signature]

Date & Phone#: 1/02/23 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**