

Day	pH	Alk	Phos	Other	Y/N
1	7.91		1.52		Y
2	7.92		1.55		Y
3	7.31		1.56		Y
4	7.60		1.54		Y
5	7.61	36.1	1.44		Y
6	7.55		1.62		Y
7	7.57		1.49		Y
8	7.45		1.66		Y
9	7.16		1.81		Y
10	7.64		1.66		Y
11	7.70		1.44		Y
12	7.62		1.39		Y
13	7.59		1.42		Y
14	7.55		1.30		Y
15	7.44		1.75		Y
16	7.36		1.48		Y
17	7.36		1.48		Y
18	7.43	37.2	1.60		Y
19	7.45		1.57		Y
20	7.50		1.41		Y
21	7.50		1.58		Y
22	7.53		1.56		Y
23	7.50		1.48		Y
24	7.49		1.45		Y
25	7.45		1.50		Y
26	7.51		1.49		Y
27	7.51		1.41		Y
28	7.50		1.40		Y
29	7.52		1.53		Y
30	7.50		1.53		Y
31					

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: April 2023  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlegel

Signature: [Signature]

Date & Phone#: 5/01/23 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's