

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.85	37.1	1.59		Y
2	7.62		1.62		Y
3	7.50		1.55		Y
4	7.47	36.9	1.92		Y
5	7.51		1.43		Y
6	7.33		1.37		Y
7	7.55		1.50		Y
8	7.47		1.50		Y
9	7.60		1.53		Y
10	7.72		1.35		Y
11	7.51		1.53		Y
12	7.59		1.63		Y
13	7.63		1.65		Y
14	7.47		1.62		Y
15	7.40		1.39		Y
16	7.45		1.44		Y
17	7.47	37.5	1.37		Y
18	7.45		1.45		Y
19	7.44		1.37		Y
20	7.39		1.57		Y
21	7.01		1.43		Y
22	7.54	36.9	1.41		Y
23	7.28		1.32		Y
24	7.20		1.49		Y
25	7.25		1.45		Y
26	7.21		1.46		Y
27	7.46		1.39		Y
28	7.45		1.35		Y
29	7.72		1.35		Y
30	7.71		1.60		Y
31	7.60		1.59		Y

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT  
EP-A  
PWS ID 4100248  
DALLAS, CITY OF**

Sample period: May 2023  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Dennis Schlegel

Signature: [Signature]

Date & Phone#: 6/02/23 503-623-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**