

Day	pH	Alk	Phos	Other	Y/N
1	7.36		1.44		Y
2	7.30		1.40		Y
3	7.22	38.0	1.42		Y
4	7.33		1.46		Y
5	7.29		1.49		Y
6	7.42	42.2	1.54		Y
7	7.40		1.48		Y
8	7.33		1.59		Y
9	7.57		1.60		X
10	7.28		1.41		Y
11	7.33		1.65		Y
12	7.24		1.41		Y
13	7.35		1.45		Y
14	7.36		1.43		Y
15	7.43		1.54		Y
16	7.33		1.50		Y
17	7.37		1.50		Y
18	7.53	44.3	1.41		Y
19	7.40		1.37		Y
20	7.39	41.5	1.43		Y
21	7.31		1.50		Y
22	7.42		1.55		Y
23	7.30		1.50		Y
24	7.36		1.54		Y
25	7.52		1.47		Y
26	7.44		1.38		Y
27	7.44		1.42		Y
28	7.36		1.47		Y
29	7.34		1.47		Y
30	7.37		1.48		Y
31	7.33		1.47		Y

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: July 2023  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson  
Signature: [Signature]  
Date & Phone#: \_\_\_\_\_ 503-673-2175

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**