

Day	pH	Alk	Phos	Other	Y/N
1	7.35		1.53		Y
2	7.23		1.53		Y
3	7.39		1.44		Y
4	7.50	39.0	1.54		Y
5	7.52		1.44		Y
6	7.51		1.52		Y
7	7.60		1.49		Y
8	7.44		1.44		Y
9	7.53		1.52		Y
10	7.52		1.56		Y
11	7.48		1.59		Y
12	7.41		1.49		Y
13	7.32		1.47		Y
14	7.67		1.34		Y
15	7.68		1.52		Y
16	7.46		1.56		Y
17	7.41	41.2	1.45		Y
18	7.50		1.39		Y
19	7.50		1.47		Y
20	7.48		1.49		Y
21	7.37		1.42		Y
22	7.22		1.78		Y
23	7.60		1.52		Y
24	7.66		1.47		Y
25	7.70	38.5	1.68		Y
26	7.68		1.68		Y
27	7.32		1.39		Y
28	7.22		1.52		Y
29	7.32		1.48		Y
30	7.24		1.55		Y
31	7.37		1.56		Y

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100248**

**DALLAS, CITY OF**

Sample period: Jan 2024  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0	
Alk	34.0	(Alkalinity)
PO4	1.3	(Orthophosphate)

Print Name: Jason Anderson

Signature: Jason Anderson

Date & Phone#: 2/11/24 503-623-2175

Send to DWP within 10 days after end of sampling period