

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Feb-2021

Day	PH	Alk	Phos	Other	Y/N
1	7.1				Y
2	7.1				Y
3	7.3				Y
4	7.8				Y
5	7.1				Y
6	7.7				Y
7	7.8				Y
8	7.5				Y
9	7.6				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.7				Y
14	7.1				Y
15	7.1				Y
16	7.1				Y
17	7.2				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.5				Y
22	7.5				Y
23	7.1				Y
24	7.3				Y
25	7.3				Y
26	7.3				Y
27	7.4				Y
28	7.5				Y
29					
30					
31					
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100254

System Name: City of Depoe Bay

Entry Point: A

Sample Period: Feb-21
Month/Year

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameter(s) as set by State:**

	MIN	
pH	7.1	
Alk		(Alkalinity)
PO4		(Orthpphosphate)
Other		()

Print Name: Brady Weidner

Signature: [Signature]

Date: 3-5-21

Sent to DWP within 10 days after end of sampling period.