

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

APRIL 2021

Day	PH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.5				Y
3	7.3				Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.4				Y
8	7.3				Y
9	7.3				Y
10	7.1				Y
11	7.3				Y
12	7.2				Y
13	7.1				Y
14	7.1				Y
15	7.5				Y
16	7.5				Y
17	7.4				Y
18	7.3				Y
19	7.4				Y
20	7.4				Y
21	7.2				Y
22	7.1				Y
23	7.1				Y
24	7.2				Y
25	7.1				Y
26	7.3				Y
27	7.2				Y
28	7.1				Y
29	7.1				Y
30	7.1				Y
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day?	ENTRY POINT	
	PWS ID:	4100254
	System Name:	City of Depoe Bay
	Entry Point:	A
Sample Period:	Apr-21	
	Month/Year	


Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:	
	MIN
pH	7.1
Alk	
PO4	
Other	
	(Alkalinity) (Orthpphosphate) ()

Print Name: Brady Weidner

Signature: 

Date: 5-7-2021

Sent to DWP within 10 days after end of sampling period.