

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

*JAN 2022*

Day	PH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.2				Y
3	7.1				Y
4	7.1				Y
5	7.2				Y
6	7.4				Y
7	7.3				Y
8	7.6				Y
9	7.2				Y
10	7.5				Y
11	7.4				Y
12	7.4				Y
13	7.1				Y
14	7.4				Y
15	7.3				Y
16	7.3				Y
17	7.3				Y
18	7.3				Y
19	7.4				Y
20	7.3				Y
21	7.2				Y
22	7.5				Y
23	7.6				Y
24	7.7				Y
25	7.5				Y
26	7.3				Y
27	7.5				Y
28	7.3				Y
29	7.6				Y
30	7.3				Y
31	7.2				Y
<b>Total N's</b> (No = N = Excursion)					<b>0</b>

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100254

System Name: City of Depoe Bay

Entry Point: A

Sample Period: Jan-22  
Month/Year

**Number of excursions during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameter(s) as set by State:**

	MIN	
pH	7.1	
Alk		(Alkalinity)
PO4		(Orthpphosphate)
Other		( )

Print Name: BRADY WEIDNER

Signature: *Brady Weidner*

Date: 2-3-22  
Sent to DWP within 10 days after end of sampling period.