

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Feb-2022

Day	PH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2				Y
3	7.1				Y
4	7.1				Y
5	7.2				Y
6	7.1				Y
7	7.2				Y
8	7.3				Y
9	7.5				Y
10	7.7				Y
11	7.4				Y
12	7.6				Y
13	7.5				Y
14	7.1				Y
15	7.1				Y
16	7.1				Y
17	7.1				Y
18	7.2				Y
19	7.1				Y
20	7.2				Y
21	7.9				Y
22	7.2				Y
23	7.1				Y
24	7.5				Y
25	7.6				Y
26	7.3				Y
27	7.2				Y
28	7.1				Y
29					
30					
31					
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100254
 System Name: City of Depoe Bay
 Entry Point: A
 Sample Period: Feb-22
 Month/Year

Number of excursions during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:	
	MIN
pH	7.1
Alk	
PO4	
Other	

(Alkalinity)
(Orthpphosphate)
()

Print Name: BRADY WEIDNER

Signature: 

Date: MARCH 7th 2022
 Sent to DWP within 10 days after end of sampling period.