

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.3				Y
3	7.3				Y
4	7.3				Y
5	7.3				Y
6	7.2				Y
7	7.1				Y
8	7.3				Y
9	7.2				Y
10	7.3				Y
11	7.3				Y
12	7.4				Y
13	7.5				Y
14	7.4				Y
15	7.6				Y
16	7.6				Y
17	7.5				Y
18	7.3				Y
19	7.3				Y
20	7.4				Y
21	7.2				Y
22	7.4				Y
23	7.7				Y
24	7.1				Y
25	7.1				Y
26	7.3				Y
27	7.4				Y
28	7.3				Y
29	#N/A				
30	#N/A				
31	#N/A				

Total N's 0

(No = N = Excursion)

Feb. 23

<<Have minimums been met for this day?	ENTRY POINT	
PWS ID:	4100254	
System Name:	City of Depoe Bay	
Entry Point:	A	
Sample Period:	Feb-23	
	Month/Year	

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:	
	MIN
pH	7.1
Alk	
PO4	
Other	
	(Alkalinity) (Orthpphosphate) ()

Print Name: *Brady Weidner*

Signature: *[Signature]*

Date: *3-6-2023*
Sent to DWP within 10 days after end of sampling period.