

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.1	60.0			Y
2	7.8				Y
3	7.8				Y
4	7.5				Y
5	7.8				Y
6	7.6				Y
7	7.8				Y
8	7.9	60.0			Y
9	7.5				Y
10	7.3				Y
11	7.2				Y
12	7.1				Y
13	7.1				Y
14	7.1				Y
15	7.3	40.0			Y
16	7.1				Y
17	7.8				Y
18	7.2				Y
19	7.2				Y
20	7.4				Y
21	7.3				Y
22	7.2	40.0			Y
23	7.1				Y
24	7.3				Y
25	7.5				Y
26	7.2				Y
27	7.1				Y
28	7.2				Y
29	7.4	40.0			Y
30	7.2				Y
31	7.2				Y
Total N's (No = N = Excursion)					

<<Have minimums been met for this day?	ENTRY POINT	
	PWS ID:	4100254
	System Name:	City of Depoe Bay
	Entry Point:	A
Sample Period:	May-24	Month/Year

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)


Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:	
	MIN
pH	7.1
Alk	24
PO4	
Other	

(Alkalinity)
(Orthpphosphate)
()

Print Name: PAUL CARVER

Signature: 

Date: 6-4-24

Sent to DWP within 10 days after end of sampling period.