

Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control

Day	PH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.3				Y
3	7.2				Y
4	7.4				Y
5	7.2	40.0			Y
6	7.2				Y
7	7.3				Y
8	7.1				Y
9	7.2				Y
10	7.2				Y
11	7.2				Y
12	7.1	40.0			Y
13	7.2				Y
14	7.4				Y
15	7.2				Y
16	7.2				Y
17	7.3				Y
18	7.1				Y
19	7.2	60.0			Y
20	7.3				Y
21	7.7				Y
22	7.2				Y
23	7.4				Y
24	7.2				Y
25	7.1				Y
26	7.5	40.0			Y
27	7.5				Y
28	7.3				Y
29	7.6				Y
30	7.3				Y
31	7.2				Y
Total N's					<u>0</u>

(No = N = Excursion)

<<Have minimums
been met for this
day?

MAY 2025

ENTRY POINT

PWS ID: 4100254

System Name: City of Depoe Bay

Entry Point: A

Sample Period: May-25
Month/Year

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the
minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameter(s) as set by State:**

	MIN	
pH	7.1	
Alk	24	(Alkalinity)
PO4		(Orthpphosphate)
Other		()

Print Name:

Brady Weidner

Signature:

[Signature]

Date:

6-6-2025

Sent to DWP within 10 days after end of sampling period.