

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.1	40.0			Y
2	7.2				Y
3	7.2				Y
4	7.3				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.2	40.0			Y
9	7.3				Y
10	7.5				Y
11	7.3				Y
12	7.2				Y
13	7.3				Y
14	7.5				Y
15	7.2	40.0			Y
16	7.3				Y
17	7.3				Y
18	7.4				Y
19	7.1				Y
20	7.1				Y
21	7.2				Y
22	7.3	40.0			Y
23	7.5				Y
24	7.4				Y
25	7.3				Y
26	7.3				Y
27	7.1				Y
28	7.3				Y
29	7.2	40.0			Y
30	7.2				Y
31	#N/A				
Total N's (No = N = Excursion)					0

Sept. 2025

<<Have minimums been met for this day?		ENTRY POINT	
PWS ID:	4100254		
System Name:	City of Depoe Bay		
Entry Point:	A		
Sample Period:	Sep-25		
	Month/Year		

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:	
	MIN
pH	7.1
Alk	24
PO4	
Other	
	(Alkalinity) (Orthpphosphate) ()

Print Name: Brady Weidner

Signature: *[Signature]*

Date: OCTOBER 1st 2025
Sent to DWP within 10 days after end of sampling period.