

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	8.0				Y
2	7.3				Y
3	7.2				Y
4	7.2				Y
5	7.2	40.0			Y
6	7.2				Y
7	7.3				Y
8	7.1				Y
9	7.6				Y
10	7.4				Y
11	7.5				Y
12	7.6	40.0			Y
13	7.6				Y
14	8.0				Y
15	7.1				Y
16	7.5				Y
17	7.2				Y
18	7.2				Y
19	7.1				Y
20	7.4	40.0			Y
21	7.6				Y
22	7.3				Y
23	7.5				Y
24	7.6				Y
25	7.4				Y
26	7.4	40.0			Y
27	7.3				Y
28	7.1				Y
29	7.3				Y
30	7.5				Y
31	7.3				Y
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day?		ENTRY POINT	
	PWS ID:	4100254	
System Name:	City of Depoe Bay		
Entry Point:	A		
Sample Period:	Jan-26		
	<i>Month/Year</i>		

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		
	MIN	
pH	7.1	
Alk	24	(Alkalinity)
PO4		(Orthpphosphate)
Other		()

Print Name: PAUL CARLEN

Signature: 

Date: 2-5-26

Sent to DWP within 10 days after end of sampling period.