

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

City of Depoe Bay

Feb - 2024

Day	PH	Al <input type="checkbox"/>	Phos	Other	Y/N
1	7.2				Y
2	7.3				Y
3	7.1				Y
4	8.0				Y
5	7.6				Y
6	7.4				Y
7	7.3				Y
8	7.4				Y
9	7.1				Y
10	7.3				Y
11	7.8				Y
12	7.6				Y
13	7.4				Y
14	7.7				Y
15	7.6				Y
16	8.1				Y
17	7.4				Y
18	7.4				Y
19	7.4				Y
20	7.8				Y
21	7.5				Y
22	7.5				Y
23	7.6				Y
24	7.7				Y
25	7.5				Y
26	7.3				Y
27	7.6				Y
28	7.6				Y
29					
30					
31					
Total N's (No = N = Excursion)					<u>0</u>

<<Have minimums been met for this day?	ENTRY POINT	
PWS ID:	4100254	
System Name:	City of Depoe Bay	
Entry Point:	A	
Sample Period:	Feb-26	
	Month/Year	

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:	
	MIN
pH	7.1
Alk	24
PO4	
Other	

(Alkalinity)
(Orthpphosphate)
()

Print Name: Brady Weicher

Signature: *[Signature]*

Date: 3-8-24
Sent to DWP within 10 days after end of sampling period.