

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Dec 22

| Day | PH | Alk | Phos | Other | Y/N |
|--|-----|-----|------|-------|----------|
| 1 | 7.1 | | | | Y |
| 2 | 7.5 | | | | Y |
| 3 | 8.2 | | | | Y |
| 4 | 7.9 | | | | Y |
| 5 | 7.9 | | | | Y |
| 6 | 7.6 | | | | Y |
| 7 | 7.5 | | | | Y |
| 8 | 7.3 | | | | Y |
| 9 | 7.4 | | | | Y |
| 10 | 7.3 | | | | Y |
| 11 | 7.1 | | | | Y |
| 12 | 7.1 | | | | Y |
| 13 | 7.6 | | | | Y |
| 14 | 7.7 | | | | Y |
| 15 | 7.9 | | | | Y |
| 16 | 7.8 | | | | Y |
| 17 | 8.0 | | | | Y |
| 18 | 7.6 | | | | Y |
| 19 | 8.0 | | | | Y |
| 20 | 7.7 | | | | Y |
| 21 | 7.4 | | | | Y |
| 22 | 7.3 | | | | Y |
| 23 | 7.3 | | | | Y |
| 24 | 7.3 | | | | Y |
| 25 | 7.3 | | | | Y |
| 26 | 7.3 | | | | Y |
| 27 | 7.1 | | | | Y |
| 28 | 7.4 | | | | Y |
| 29 | 7.7 | | | | Y |
| 30 | 7.1 | | | | Y |
| 31 | 8.3 | | | | Y |
| Total N's (No = N = Excursion) | | | | | 0 |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100254

System Name: City of Depoe Bay

Entry Point: A

Sample Period: Dec-22
Month/Year

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameter(s) as set by State:**

| | | |
|-------|-----|------------------|
| | MIN | |
| pH | 7.1 | |
| Alk | | (Alkalinity) |
| PO4 | | (Orthpphosphate) |
| Other | | () |

Print Name: Brady Heindler

Signature: 

Date: _____
Sent to DWP within 10 days after end of sampling period.